



## **ADDENDUM 1**

---

**DATE:** May 13, 2025  
**FROM:** Millies Engineering Group  
**Project:** 20231372 NW818 Marram Hall – Room 303 Replace HVAC Units  
**PROJECT NO:** 2025-03-048

---

**A. DRAWINGS:**

**1. SHEET E3**

- a. Revise sheet number and title to "M/E3 – Electrical Schedules, Details, Diagrams and Mechanical Specifications".
- b. Add the following sentence to specification section 1.1 "Provide temporary cooling to maintain 75 degree F space temperature during construction".

**A. DRAWINGS:**

**1. XX**

**END OF Addendum 1**