# **ADDENDUM**



ADDENDUM NO: 03

PROJECT: IU BL563 Innovation Center RM139A/141 - New Wet Lab

PROJECT NO: CSO - 2025044 DATE: 10/27/2025 BY: Nick Wissing

IU - 20250201

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

Addendum Pages: ADD 1 of 2 through ADD 2 of 2

Attached Documents: NONE

Attached Specifications: NONE

### **PART 0 - GENERAL INFORMATION**

**NONE** 

### **PART 1 - BIDDING REQUIREMENTS**

NONE

### **PART 2 - SPECIFICATIONS**

**NONE** 

## **PART 3 - DRAWINGS**

NONE

#### **PART 4 - OTHER ITEMS**

NONE

## **PART 5 - QUESTIONS AND ANSWERS**

- 5.1 Question: Does anyone know the elevation of the sanitary line where the tie-in takes place?
  - 1. Answer: It should be approximately 2'-6" but the contractor should verify this dimension in the field.



- 5.2 <u>Question:</u> Can you confirm the shelf material for W1-3 and W5? W4 is clearly called out as metal but the other shelving is not noted either
  - 1. W1-3 shelving is plastic laminate clad shelves with metal support brackets. The metal support brackets should match the metal shelving of W4.

### **END ADDENDUM**

Addendum ADD 2 of 2