



BIDDING & CONTRACT REQUIREMENTS

Document 00 20 00 - Addendum No. 2

DATE: December 11, 2025

Project Engineer: RTM Engineering Consultants
20 N.W. 3rd Street Suite 510
Evansville, Indiana 47708-1356
Telephone: 812-401-2260

TO: PROSPECTIVE BIDDERS

SUBJECT: ADDENDUM NO. 2 TO THE BIDDING DOCUMENTS FOR

SE878D Meadow Lodge - HVAC and Roof Replacement
Indiana University Southeast
IU 20241304

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, date November 07, 2025. Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

DRAWINGS:

1. Sheet M401 – MECHANICAL SCHEDULES:
 - a. Modify “CONDENSING UNIT SCHEDULE” model number to be first 5 digits only.
 - b. Modify “CONDENSING UNIT SCHEDULE” Note 1 to read as follows:

“PROVIDE CONDENSING UNIT WITH: SINGLE-STAGE SCROLL COMPRESSOR; LOUVERED HAIL GUARDS; SERVICE VALVES; LOW AMBIENT PRESSURE SWITCH; CRANKCASE HEATER; EVAPORATOR FREEZE THERMOSTAT; HARD START KIT; HIGH PRESSURE SWITCH; LOW PRESSURE SWITCH; AND FILTER DRYER.”