

**IU072- SL Bldg
Replace AHU-0 East
Air Handling Unit Pre-Purchase**

**IUI
723 W. Michigan St.
Indianapolis, Indiana
IU 20250575**

ADDENDUM NO. 1

HEAPY PROJECT NO. 2025-06079

December 22, 2025

SPECIFICATIONS

ITEM NO. 1 01 10 00

- A. Modify Paragraph 1.4.B to read as follows:
 - a. “B. All electrical components shall ship loose for installation and wiring by the on-site contractors; this includes the lights, light conduit, motor conduit, motor wire, exterior junction boxes or non-fused disconnects where specified.”

ITEM NO. 2 23 73 23

- A. Delete paragraph 2.14.A.
- B. Modify paragraph 2.14.C to read as follows:
 - a. “C. Unit manufacturer shall provide components for the complete electrical system and all branch circuit wiring and conduit. All electrical components shall ship loose for installation and wiring by the on-site contractors; this includes the lights, light conduit, motor conduit, motor wire, exterior junction boxes or non-fused disconnects where specified.”