

Bid

Addendum 1

**IU Bloomington- Poplars Parking
Garage**

415 East 6th Street

Bloomington, IN

**IU Bloomington- Atwater Parking
Garage**

921 Atwater Avenue

Bloomington, IN

Project:

**BL000B – Multi-Building: Elevator Installation BL009
Poplars and BL069 Atwater**

INDIANA UNIVERSITY Bloomington

IU 20251235

VDA, Inc.

Indianapolis, IN

(317) 973-0211

**INDIANA
UNIVERSITY**



**CAPITAL PLANNING
AND FACILITIES**

2901 East Discovery Parkway

Bloomington, IN 47408





04/28/2026

ADDENDUM NO. 1

POPLARS PARKING GARAGE

ELEVATOR MODERNIZATION

415 EAST 6TH STREET

BLOOMINGTON, IN

IU 20251235

SECTION 14 21 23

Please make sure to recognize all addendums when bidding.

The following answers, clarifications and changes apply to the project specifications and bid form:

1. ***Bid Date Has changed to May 8, 2026 at 2:00 PM***
2. *Question: We want to verify that you would like to have all costs for hole drilling vac trucks, etc. associated with the new cylinders at Poplar and Atwater included in our bid. Response: Cost to Cover additional Drilling required upon removal of the existing Jack is to be included in the base price for all four Elevators. It is requested that Each bidder provide informational pricing for the Drilling and or vac Trucks included for each elevator.*
3. *Question: The spec is calling for 2019 video monitoring, is that supposed to be in the spec? Response: Indiana University has requested that these elevators Include this feature understanding that it is not currently required by code in the state of Indiana.*
4. *Question: Are new Cab Shells Required? Yes Cab shells and new cab interior finishes are to be provided for these elevators per the specifications.*
5. *Elevator entrance frames will be retained any rusting on entrance frames at Poplars Garage is to be repaired and painted to match existing paint color on Entrance Frames.*