



INDIANA UNIVERSITY
CAPITAL PROJECTS

Addendum #1

Project: BL601 Memorial Stadium – Replace North Fascia LED Display
IU 20261143

Date: May 29, 2026

This Addendum, issued prior to bidding, alters, amends, corrects, or clarifies the Construction Bid Documents to the extent stated herein and does thereby become a part of the Construction Bid Documents, and will become part of the Contract Documents of the successful bidder. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

ITEMS INCLUDED IN THIS ADDENDUM

1. See attached pre-bid meeting sign-in sheet.
2. The site is to be accessed from the field-level overhead door in SW corner of Memorial Stadium and along the rubber track surface to the project location. Provide plywood protection along route and below work occurring on the fascia display.
3. The existing canopy structure located below a portion of the fascia display is to be moved by owner.
4. A top-service or front-service fascia display will be acceptable.
5. The electrical panel serving the fascia display is in room N085 of the north end zone building.
6. The equipment racks serving the fascia display are in room W713 of the press box.

Attachments

5/20/26 Pre-bid meeting sign-in sheet

End of Addendum No. 1

PRE-BID

20261143 MEMORIAL STADIUM NORTH FASCIA LED

NAME

COMPANY

EMAIL

JEFF MOULDEN

IU CAF

JMOULDEN@IU.EDU

MATT SMETHURST

IU CPF

MSMETHUR@IU.EDU

Shawn Trendelman Cassidy

Shawn.Trendelman@

~~Brian Hulley~~

~~IU AT&T~~

~~Cassidy electric.com~~

Brian Hulley

IU AT&T

bhulley@iu.edu

Scott Whitmer

DAKTRONICS

Scott.Whitmer@daktronics.com

George Marsico

Mitsubishi Electric

george.marsico@meppi.com